Date	21/07 AM	21/07 PM	22/07 AM	22/07 PM	23/07 AM	23/07 PM	24/07 AM	24/07 PM	25/07 AM	25/07 PM	26/07 AM	26/07 PM	27/07 AM	27/07 PM	28/07 AM	28/07 PM	29/07 AM	29/07 PM	30/07 AM	30/07 PM	31/07 AM	31/07 PM	01/08 AM	01/08 PM
MW away from risk of System Level NRAPM (Forecast Conditions)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0								
MW away from risk of Scotland Level NRAPM (Forecast Conditions)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0								

Week Number	30W18	31W18	32W18	33W18	34W18	35W18	36W18	37W18	38W18	39W18	40W18	41W18	42W18	43W18	44W18	45W18	46W18	47W18	48W18	49W18	50W18	51W18	52W18	01W19	02W19	03W19	04W19	05W19	06W19	07W19	08W19	09W19	10W19	11W19	12W19	13W19	14W19	15W19	16W19	17W19	18W19	19W19	20W19	21W19	22W19	23W19	24W19	25W19	26W19	27W19	28W19
Date	29/07/2018	05/08/2018	12/08/2018	19/08/2018	26/08/2018	02/09/2018	09/09/2018	16/09/2018	23/09/2018	30/09/2018	07/10/2018	14/10/2018	21/10/2018	28/10/2018	04/11/2018	11/11/2018	18/11/2018	25/11/2018	02/12/2018	09/12/2018	16/12/2018	23/12/2018	30/12/2018	06/01/2019	13/01/2019	20/01/2019	27/01/2019	03/02/2019	10/02/2019	17/02/2019	24/02/2019	03/03/2019	10/03/2019	17/03/2019	24/03/2019	31/03/2019	07/04/2019	14/04/2019	21/04/2019	28/04/2019	05/05/2019	12/05/2019	19/05/2019	26/05/2019	02/06/2019	09/06/2019	16/06/2019	23/06/2019	30/06/2019	07/07/2019	14/07/2019
Wind Load Factor required to cause a System Level NRAPM	1.12	0.97	0.98	1.03	1.08	1.09	0.99	1.08	1.09	1.04	1.03	1.02	1.00	0.99	0.99	1.01	1.05	1.01	0.99	1.01	1.03	1.04	1.08	1.01	1.00	1.02	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04	1.03	1.04
Probability of seeing Wind load factor above	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	5%	3%	5%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%	3%	5%	5%
Wind Load Factor required to cause a Scotland Level NRAPM	1.55	1.51	1.50	1.51	1.53	1.61	1.50	1.62	1.63	1.60	1.68	1.65	1.56	2.14	1.97	1.68	1.66	1.70	1.61	1.70	1.64	1.57	1.62	1.54	1.71	1.53	1.56	1.70	1.60	1.64	1.65	1.65	1.70	1.60	1.64	1.70	1.61	1.65	1.65	1.57	1.66	1.54	1.71	1.68	1.55	1.56	1.55	1.71	1.67
Probability of seeing Wind load factor above	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%

The forecast is meant as a guide and does not take into account action on pump storage or Inclerconnectors which will be done as required in control room timescales.
The RAG for the 7-14 National level is based on a surplus higher than 1700MW for green, between 900 and 1700MW for amber and less than 900MW for Red it includes a MW level away from the risk
The RAG for the 2-14 Scottish level is based on a surplus higher than 400MW for green, between 0 and 400MW for amber and below 0MW for Red it includes a MW level away from the risk.

The weekly 2-52 RAG is the load factor of wind required to cause an NRAPM and then the % probability of getting this load factor. So the percentage can be read as the probability of an NRAPM for each week in with yellow for between 5% and 20% and Red for over 20%.