








Grid Code Modification Proposal Form		At what stage is this document in the process?
<h1>GC0111:</h1> <p><b>Mod Title:</b> Fast Fault Current Injection specification text</p>		<div>01 Proposal Form</div> <div>02 Workgroup Consultation</div> <div>03 Workgroup Report</div> <div>04 Code Administrator Consultation</div> <div>05 Draft Grid Code Modification Report</div> <div>06 Final Grid Code Modification Report</div>
<p><b>Purpose of Modification:</b> To update the Grid Code and G99 with revised text for fast fault current injection to dispel any confusion in interpretation of the existing text.</p>		
	This document contains the discussion of the Workgroup which formed in July 2018 to develop and assess the proposal, the voting of the Workgroup held on [Date] and the Workgroup's final conclusions.	
	<b>High Impact:</b> None	
	<b>Medium Impact:</b> Manufacturers, installers and owners of Type B to Type D power park modules connected to both distribution and transmission systems	
	<b>Low Impact:</b> None	

Contents		 Any questions?
1 Summary	Error! Bookmark not defined.	Contact: Matthew Bent <b>Code Administrator</b>
2 Governance	Error! Bookmark not defined.	 <a href="mailto:matthew.bent@nationalgrid.com">matthew.bent@nationalgrid.com</a>
3 Why Change?	5	 077854 28175
4 Code Specific Matters	Error! Bookmark not defined.	<b>Proposer:</b> Mike Kay, P2 Analysis Limited  (nominated by Steve Cox, Electricity North West)
5 Solution	Error! Bookmark not defined.	
6 Impacts & Other Considerations	Error! Bookmark not defined.	
7 Relevant Objectives	Error! Bookmark not defined.	
8 Implementation	Error! Bookmark not defined.	
9 Legal Text	Error! Bookmark not defined.	 <a href="mailto:mikekay@P2Analysis.co.uk">mikekay@P2Analysis.co.uk</a>
10 Recommendations	Error! Bookmark not defined.	
<b>Timetable</b> <i>The Code Administrator will update the timetable.</i>		 07768038913
<b>The Code Administrator recommends the following timetable:</b> <i>(amend as appropriate)</i>		<b>National Grid Representative:</b> <b>Tony Johnson</b>
Initial consideration by Workgroup	4 July 2018	
Modification concluded by Workgroup	February 2019	 <a href="mailto:Antony.Johnson@nationalgrid.com">Antony.Johnson@nationalgrid.com</a>
Workgroup Report presented to Panel	28 February 2019	
Code Administration Consultation Report issued to the Industry	w/c 4 March 2019	 01926 655466
Draft Final Modification Report presented to Panel	28 March 2019	
Modification Panel decision	28 March 2019	
Final Modification Report issued the Authority	w/c 1 April 2019	
Decision implemented in Grid Code	w/c 13 May 2019	

## 1 About this document

This document is the Workgroup Report containing the discussion of the Workgroup which formed in July 2018 to develop and assess the proposal and the voting of the Workgroup held on [Date].

GC0111 was proposed by P2 Analysis Limited and was submitted to the Grid Code Review Panel for its consideration on 26 April 2018. The Panel decided to send the Proposal to a Workgroup to be developed and assessed against the Grid Code Applicable Objectives.

GC0111 aims to amend the Grid Code to provide revised text in relation to fast fault current injection to dispel any confusion in relation to the existing text within the Grid Code.

### **Workgroup Conclusions**

At the final Workgroup meeting, Workgroup members voted on the Original proposal. [Insert number of WG members] members voted that the Original Proposal better facilitated the applicable Grid Code objectives.

Section 2 (Original Proposal) and Section 3 (Proposer's solution) are sourced directly from the Proposer and any statements or assertions have not been altered or substantiated/supported or refuted by the Workgroup. Section 5 of the Workgroup contains the discussion by the Workgroup on the Proposal and the potential solution.

The Grid Code Review Panel detailed in the Terms of Reference the scope of work for the GC0111 Workgroup and the specific areas that the Workgroup should consider.

The table below details these specific areas and where the Workgroup have covered them or will cover post Workgroup Consultation.

The full Terms of Reference can be found in Annex 1.

Table 1: GC0111 Terms of Reference

Specific Area	Location in the report
a) Implementation and costs	Section 3 and 4
b) Review draft legal text should it have been provided. If legal text is not submitted within the Grid Code Modification Proposal the Workgroup	Section 4 and 8

should be instructed to assist in the developing of the legal text.	
c) <i>Consider whether any further Industry experts or stakeholders should be invited to participate within the Workgroup to ensure that all potentially affected stakeholders have the opportunity to be represented in the Workgroup. Demonstrate what has been done to cover this clearly in the report</i>	Section 4
d) Consider materiality of change	Section 4
e) Workgroup consultation and whether required	Section 4
f) Review the trigger voltage and FRT requirements and whether compatible.	Section 4

## 2 Original Proposal

### Defect

The Grid Code (and Distribution Code) modification being implemented in GC0100 has recast the long-standing Grid Code Fast Fault Current Injection (FFCI) requirements in a way that is phrased so as to be compatible with the Requirements for Generators (RfG). However, the wording chosen is open to misinterpretation and has induced some confusion amongst a small number of stakeholders.

### What

The specification and testing requirements for FFCI need to be clarified in the Grid Code – and this clarification fed into G99 which also needs to be updated to reflect this.

### Why

Manufacturers of Power Park Modules need clarity on the FFCI requirements so that then can ensure compliance at the point of manufacture. It is not possible to test for compliance with the FFCI requirements on site, so it is crucially important that the requirements are specified with complete clarity and freedom from ambiguity.

## How

The Grid Code and Engineering Recommendation (EREC) G99 will need to be modified post clarification of the compliance requirements.

### 3 Proposer's solution

The requirements for FFCI as specified in ECC 6.3.16.1 and G99 12.6 and 13.6 will need to be updated following agreement in the Workgroup as to the precise requirements that need to be complied with.

In GC0100 new requirements were introduced into the Grid Code in respect of fast fault current injection. These requirements apply only to Power Park Modules. Prior to the introduction of RfG, there was a loose requirement for fast fault current injection although this simply stated that each Power Park Module shall generate maximum reactive current without exceeding the transient rating of the limit of the Power Park Module and/or any constituent Power Park Unit.

On the other hand RfG (Article 21(3)) specifies a much more detailed requirement with respect to the reactive current injection requirements. These issues and the approach to implementation were covered in consultation GC0100 which is available from the following link.

[https://www.nationalgrideso.com/sites/es0/files/documents/Final%20Workgroup%20consultation\\_0.pdf](https://www.nationalgrideso.com/sites/es0/files/documents/Final%20Workgroup%20consultation_0.pdf)

Shortly after the consultation, and after the proposals had been submitted to the Authority, a number of comments were received in relation to the clarity over the interpretation of fast fault current injection. These mainly related to the plant rating, how the injected current may vary in phase and magnitude with respect to both voltage deviation and time.

The first meeting was held in July 2018 to articulate the scope of the problem and define that there would be no requirement for the rating of the Power Park Module to be exceeded. The slides for this first meeting are attached in Annex 1. Of importance during this meeting was the introduction of a concept to specify that the rating of the Power Park Module was not expected to be exceeded.

Figure 1.0 below shows a typical wind farm comprising one Power Park Module. Under a faulted condition where the voltage at the connection point falls to zero the intention would be for the Power Park Module to supply full reactive current without the rating of the Power Park Module or HVDC System from being exceeded.




Figure 1.0

The rating of the Power Park Module or HVDC System is calculated on the basis of the rated MW output at maximum Reactive Power Output. Taking the example of the wind farm shown in Figure 1.0 below, if the Rated MW output was 100MW and under ECC.6.3.2.4 the reactive capability requirement is 0.95 Power Factor lead to 0.95 Power Factor lag, which requires a reactive capability of  $\pm 32.9\text{MVar}$  the rating of the Power Park Module becomes 105.3 MVA (ie  $\sqrt{(100^2 + 32.9^2)}$ ) or 1.0pu on Rated MVA (ie  $105.3/105.3$ ).

Under a faulted condition, the fall in voltage will result in a consequential increase in reactive current to the point where at zero voltage at the connection point the full reactive current injection. As noted above, the reactive current injection would not be required to exceed the rating of the Power Park Module or HVDC System.

Figure 2.0 below shows how the real and reactive current varies. The locus (ie the circle) being the rating of the Power Park Module or HVDC Converter which in this example is 1.0pu on the MVA base of the Power Park Module or 105MVA.





Figure 2.0

In the event of a fault, Figure 3.0 shows the blue vector and blue dashed vector moving towards the x axis (ie an increase in reactive current supply as compared to the red and green vector which forms the boundary between when the Power Park Module is operating in a steady state condition (ie operation between 0.95 lead and 0.95 lag).



The current drafting of ECC.6.3.16 and G99 12.6 and 13.6 does not make this clear. The second deficiency is that it is not clear how the reactive current would vary with depressed voltage.

At its highest level, National Grid has a number of fundamental requirements when it comes to ensuring the robustness of the system under fault conditions. These are summarised as follows:-

Criteria	Requirement
Fault Ride Through	Power Generating Modules to remain connected and stable for up to 140ms in duration for both balanced and unbalanced faults which would include a close up solid three phase short circuit adjacent to the Connection Point
	Power Generating Modules to remain connected and stable for any balanced fault in excess of 140ms so long as the retained voltage is above the heavy black line specified in ECC.6.3.15.9 and ER G99 12.6 and 13.6.
Fast Fault Current Injection	Reactive current injection required each time the voltage falls below the nominal voltage levels in ECC.6.1.4. The reactive current injected should be function of the retained voltage with any residual current being supplied as active current.  There should be a smooth control between steady state operation and faulted conditions

These criteria are important. The requirements for fault ride through are well documented in numerous texts and the reader is encouraged not only to refer to the material included in the appendices within this report but also Grid Code Consultation GC0100 which is available from the link below.

[https://www.nationalgrideso.com/sites/eso/files/documents/Final%20Workgroup%20consultation\\_0.pdf](https://www.nationalgrideso.com/sites/eso/files/documents/Final%20Workgroup%20consultation_0.pdf)

In summary when a generator is exposed to a close up solid three phase short circuit fault there is a requirement to inject maximum reactive current so as to maintain System voltage and for longer term voltage dips there is a requirement for a contribution of reactive current with the residual to be supplied as Active Current so as to contribute to Active Power, this being important criteria for the support of system frequency in the event of a voltage dip.

As an initial starting point, the German model was first considered as shown in Figure 4.0 where the injected reactive current is a function of the voltage.




Figure 4.0

This interpretation uses the following formula's

$$I_R = \Delta V \cdot k + I_{Prefault}$$

$I_R$  – The Reactive Current injected in pu during the fault in pu. This cannot exceed 1.0pu on the MVA Rating

$$V = V_{prefault} - V_{deadband} - V_{retained}$$

$V_{prefault}$  – Is the Prefault Postive Phase Sequence voltage in pu

$V_{deadband}$  - Is the deadband either side of nominal voltage set at 0.1pu

$V_{retained}$  – Is the positive sequence voltage at the Grid Entry Point or User System Entry Point under faulted conditions

$K$  – Is the voltage gain factor set to 1

$I_{prefault}$  – Is the prefault reactive current in pu.



These concepts were further explored and presented to the workgroup in September 2018, which resulted in the following revised voltage / reactive current diagram shown in Figure 5.0.




Figure 5.0

In addition, corresponding legal text was also developed. At this stage, a number of workgroup members expressed concern over the behaviour of Power Park Modules and HVDC Systems during unbalanced faults and that the performance of plant can vary quite significantly between full converter based plant or DFIG derived equipment. A number of concerns were also expressed with regard to operation between steady state and under faulted conditions.

At this stage two options were suggested by the workgroup. One was to consider the approach adopted as discussed in September, another was to adopt an approach similar to that proposed in EN 50549. EN50549 is much more specific in its treatment of unbalanced injection and the use of positive, negative components. These issues start to become complex very quickly and whilst two versions of the legal text were drawn up (ie one drawn up based on the discussion held in September and one drawn up based on EN 50549) the general view was that the initial approach suggested in September should be the one taken forward as the EN50549 is complex with the conclusion that any form of individual phase behaviour would be outside the scope of the workgroup.

However some very useful findings came out of these discussions in which it was agreed that in adopting the September option, the deadband should be changed to insensitivity and a number of detailed examples should also be prepared outlining how a plant would be expected to respond when operating in full lead or full lag and then subsequently exposed to range of voltage dips of various degrees ranging from 85% retained voltage to 10% retained voltage.

In addition, to reflect the difference between different technologies (ie full converter or DFIG etc), a relaxation was introduced into the drafting which effectively a permitted temporary drop below the shaded area provided this was agreed with National Grid. There is some concern how this could be interpreted and as such solution would be to

ensure the volume of reactive current supplied exceeds the minimum requirement specified.

In light of these discussions a further presentation (with examples) and revised legal text was presented to the workgroup in December 2018. A copy of this presentation is shown in Annex 2D which includes the examples.

The revised voltage / reactive current characteristic is shown in Figure 6.0 below.




Figure 6.0

Where the corresponding formula's are:-

Where:-

$V_N$  – Rated Voltage

$V$  - Actual voltage at the Grid Entry Point or User System Entry Point during the fault

$I_R$  - Additional reactive current where: \_

$$I_R = \Delta V_{1.k} + I_{Prefault} \quad (\text{when } V \text{ is between } 50\% \text{ and less than } 90\%)$$

$$I_R = I_{RMAX} \quad (\text{when } V \text{ is less than } 50\%)$$

as defined by Figure ECC.16.3.16(b) or Figure ECC.16.3.16(c))

( $I_R$  - Is the additional Reactive Current injected during the fault in per unit. This cannot exceed 1.0pu on the MVA Rating of the Power Park Module or HVDC Equipment as detailed in ECC.6.3.16.1.5)

In this approach where the voltage exceeds 50% the formula  $I_R = \Delta V_{1.k} + I_{Prefault}$  and below 50% retained voltage, full reactive current would be required to be supplied.

At this point a number of stakeholders expressed concern over the mode change at retained voltages of 50% and at this meeting it was suggested that a formula based approach should be used over the entire voltage operating range. As a result the following approach formula was proposed which would apply over the full voltage range.

V Actual voltage at the Grid Entry Point or User System Entry Point during the fault

$I_R$  The reactive current supplied under fault conditions where:-

$$I_R = \Delta V_1 \cdot k + I_{Prefault} \quad (1)$$

$I_R$  The Reactive Current supplied under fault conditions shall be above the shape shown in Figure ECC.16.3.16(b) and Figure ECC.16.3.16(c) with the peak steady state reactive current defined by Equation (1) above. This value is capped at a maximum of 1.0pu.

There is no requirement for  $I_R$  to exceed 1.0pu ( $I_{RMAX}$ ) but this would not preclude a Power Park Module (or any constituent Power Park Unit) or HVDC Equipment from supplying more should it wish to do so.

$$\Delta V_1 = V_{prefault} - V_{insensitivity} - V_{retained}$$

$V_{prefault}$  Is the Prefault Positive Phase Sequence RMS voltage in per unit

$V_{insensitivity}$  Is the voltage either side of nominal voltage and set at any value between 0 and 0.1 as agreed between The Company and the Generator - Default setting 0.1 unless otherwise agreed.

$V_{retained}$  Is the retained positive sequence voltage at the Grid Entry Point or User System Entry Point (under fault conditions)

k Is the gain factor (range proposed 2 – 7) – Default setting 2.5

$I_{prefault}$  is the prefault reactive current in per unit

The prefault reactive current ( $I_{prefault}$ ) for a future fault ride through event, shall be determined when the voltage has returned above the minimum levels specified in ECC.6.1.4,

$I_{RMAX}$  The maximum current which shall, as a minimum, be above the shaded areas defined by Figures ECC.16.3.16(b) or ECC.16.3.16(c). There is no requirement for the maximum supplied current to exceed 1.0pu.

Numerous examples of this approach at the extreme operating range (ie low and high pre-fault voltages) were prepared and these are shown in Appendix X and forwarded to the workgroup in January 2019.

For completeness two examples are shown below. In both cases the retained voltage is set at 50% with one case operating at a low pre-fault voltage and in another a high pre-fault voltage.

First Example –

### Power Park Module operating at full MW output and full MVar output – volt drop to 50% and $V_{\text{insensitivity}}$ set to 0.1 and $K = 2.5$

- Wind farm is operating at 100MW output and 0.95 PF lagging (ie 32.8MVar or export to the System)
- $I_R = \Delta V_1 \cdot k + I_{\text{Prefault}}$
- And  $\Delta V_1 = V_{\text{prefault}} - V_{\text{insensitivity}} - V_{\text{retained}}$
- If  $V_{\text{Prefault}} = 0.96 \text{ p.u}$  and  $Q_{\text{max}} = 0.95 \text{ PF lag}$  on a 4% droop
- $V_{\text{insensitivity}} = 0.1 \text{ p.u}$
- In this case the retained voltage ( $V_{\text{retained}}$ ) is 0.5 pu
- $\Delta V_1 = V_{\text{prefault}} - V_{\text{insensitivity}} - V_{\text{retained}} = 0.96 - 0.1 - 0.5 = 0.36$
- $I_{\text{prefault}} = \sin(\arccos 0.95) = 0.312 \text{ pu}$
- $I_R = \Delta V_1 \cdot k + I_{\text{Prefault}} = 0.36 \times 2.5 + 0.312 = 1.212 \text{ pu} - \text{capped at } 1.0 \text{ pu reactive current}$
- $IR \text{ at } 60\text{ms} = (0.65 \times \Delta V_1 \cdot k) + I_{\text{prefault}} = 0.65 \times 2.5 \times 0.36 + 0.312 = 0.897 \text{ pu}$

Which when superimposed on Figure ECC.6.3.16(b) and ECC.6.3.16(c) results in Figure 7.0 and Figure 8.0




Figure 7.0




Figure 8.0

#### Second Example

### Power Park Module operating at full MW output and full MVar output – volt drop to 50% and $V_{insensitivity}$ set to 0.1 and $K = 2.5$

- Wind farm is operating at 100MW output and 0.95 PF leading (ie 32.8MVar or import to the System)
- $I_R = \Delta V_1 \cdot k + I_{Prefault}$
- And  $\Delta V_1 = V_{prefault} - V_{insensitivity} - V_{retained}$
- If  $V_{Prefault} = 1.04 \text{ p.u}$  and  $Q_{max} = 0.95 \text{ PF}$  lead on a 4% droop
- $V_{insensitivity} = 0.1 \text{ p.u}$
- In this case the retained voltage ( $V_{retained}$ ) is 0.5 pu
- $\Delta V_1 = V_{prefault} - V_{insensitivity} - V_{retained} = 1.04 - 0.1 - 0.5 = 0.44$
- $I_{prefault} = \sin(\arccos 0.95) = -0.312 \text{ pu}$
- $I_R = \Delta V_1 \cdot k + I_{Prefault} = 0.44 \times 2.5 - 0.312 = 0.788 \text{ pu}$
- $IR \text{ at } 60\text{ms} = (0.65 \times \Delta V_1 \cdot k) + I_{prefault} = (0.65 \times 2.5 \times 0.44) - 0.312 = 0.403 \text{ pu}$

Which when superimposed on Figure ECC.6.3.16(b) and ECC.6.3.16(c) results in Figure 9.0 and Figure 10.0




Figure 9.0




Figure 10.0

As can be seen in the leading example the injection of reactive current is lower than that in the leading case which means that the gain factor (K) would need to be increased if full reactive current was to be achieved for a voltage drop of 50%. Whilst it is accepted that the delta (ie the reactive current swing between the two is broadly similar, full reactive injection would be required under a faulted condition.

To address this concern, the effect can be limited by changing the formula so that the additional reactive current becomes  $I_R = \Delta V_{1.k} + |I_{prefault}|$  where  $I_{prefault}$  becomes the modulus of  $I_{prefault}$  and  $\Delta V_1$  simply becomes  $V_{prefault} - V_{retained}$ . Whilst there will be a slight difference between the reactive current injected between unity power factor and full lead or full lag, full reactive current would be obtained for a retained voltage of 0.5pu. This also means the K factor can be retained at 2.5 although in simplifying the formula this would require the need to make sure developers and manufacturers are comfortable with the transition from the steady state mode between the normal operational voltage of 0.9pu

to 1.05pu and a faulted condition. The revised voltage drop / reactive current characteristic is shown in Figure 11.0.




Figure 11.0

Where:-

$V$  - Actual voltage at the Grid Entry Point or User System Entry Point during the fault

$I_R$  - The reactive current supplied under fault conditions where:-

$$I_R = \Delta V_1 \cdot k + |I_{\text{Prefault}}| \quad \text{Equation (1)}$$

$I_R$  The Reactive Current supplied under fault conditions shall be above the shape shown in Figure ECC.16.3.16(b) and Figure ECC.16.3.16(c) with the peak steady state reactive current defined by Equation (1) above. This value is capped at a maximum of 1.0pu.

There is no requirement for  $I_R$  to exceed 1.0pu ( $I_{R\text{MAX}}$ ) but this would not preclude a Power Park Module (or any constituent Power Park Unit) or HVDC Equipment from supplying more should it wish to do so.

$|I_{\text{Prefault}}|$  is the modulus of the prefault reactive current in per unit the prefault reactive current ( $I_{\text{Prefault}}$ ) for a future fault ride through event, shall be determined when the voltage has returned above the minimum levels specified in ECC.6.1.4,

$$\Delta V_1 = 0.9 - V_{\text{retained}}$$

$V_{\text{prefault}}$  Is the Prefault Positive Phase Sequence RMS voltage in per unit

$V_{\text{retained}}$  Is the retained positive sequence voltage at the Grid Entry Point or User System Entry Point (under fault conditions)

$k$  Is the gain factor (range proposed 2 – 7) – Default setting 2.5

$I_{RMAX}$  There is no requirement for the maximum supplied reactive current to exceed 1.0pu.




Figure 12.0




Figure 13.0

The key documents affected by this modification proposal are the Grid Code and EREC G99. There are no other effects on other industry documents.

**Does this modification impact a Significant Code Review (SCR) or other significant industry change projects, if so, how?**

No

### Consumer impacts

There are no consumer impacts



## 4 Workgroup Discussions

The Workgroup convened four times between July 2018 and February 2019 to discuss the perceived issue, detail the scope of the proposed defect, devise potential solutions and assess the proposal in terms of the Applicable Grid Code Objectives. The Workgroup will in due course conclude these tasks after this consultation (taking account of responses to this consultation).

Commented [NG1]: As of 18 January 2019

The Workgroup discussed a number of the key attributes under GC0111 and these discussions are described below.

### Workgroup 1 – 4 July 2018

The slides presented by National Grid as Electricity System Operator are attached in Annex 2A. In summary, this concentrated on the background to the issue, the defect and the key clarification that during a fault there is no requirement for the Power Park Module to exceed its rating. In addition, the point was also raised with regard to the defect in ECC.6.3.16.1.4 which states “the reactive current injected from each Power Park Module or HVDC Equipment shall be injected in proportion and remain in phase to the change in System voltage at the Connection Point or User System Entry Point during the period of the fault.

At the workgroup it was advised that some form of specification would be required to detail how the reactive current should vary with depressed voltage and address the linkage between the fault ride through requirements in ECC.6.3.15 and the fast fault current requirements in ECC.6.3.16.

### Workgroup 2 – 10 September 2018

A presentation was presented by the National Grid Electricity System Operator (NGESO) representative to the Workgroup which is attached in Annex 2B. The NGESO representative advised that the aim of the legal text would be to keep the requirements as generic but robust as possible. The following is the discussion on the proposed draft legal text as of 10 September 2018.

A Workgroup member stated that he found it difficult to follow all of the proposed graphs and therefore suggesting to only keep the graphs for Transmission connections but it may be useful to specify a description which would be equally effective.

A Workgroup member stated that in Figure ECC.16.3.16(a), a statement on what the maximum voltage and proportionality criteria needed to be clarified. It was agreed that this is what the graph was trying to achieve.

A Workgroup member queried whether the figures in ECC.16.3.16(a) are absolute figures. The NGESO representative tried to address this issue but further thought and clarity was needed for the legal text.

The NGESO representative referred to Figure ECC.3.16(b) and stated that the Workgroup needs to consider whether this would be a rise time or a settlement time. He explained that the reactive current has to be above the red section on the figure. The control performance should be adequately damped.

Another Workgroup member stated that their comments had already been addressed and they will forward some comments by E Mail to aid the drafting of the legal text.

A Workgroup member queried how the changes on RfG were going to be taken forward. The NGESO representative confirmed that the RfG requirements were captured in GC0100 and these have now been implemented into the Grid Code. However, it did not capture faults greater than 140 ms which have been retained as part of the existing GB Code drafting.

A Workgroup member stated that it is common for type tests to be completed for fault ride through. There may not be clear testing requirements so this will need some clarity.

The NGESO representative informed the Workgroup that it was discussed that it is not possible to demonstrate on a module basis but you can do so on individual turbines basis. There is a challenge in articulating this in the Grid Code legal text as the Grid Code is based around a performance requirement for the module rather than the turbine. Although the text is written with respect to Power Park Module performance, the proposed text does provide a clause for assessment at a unit level.

A workgroup member queried what would happen if the voltage drops below 1 per unit i.e. what would be the consequences as the Power Park Module could include various combinations as there is a phase between operation within the normal voltage operating range (ie  $\pm 10\%$ ) and under fault ride through conditions. The NGESO representative stated that they would review this when looking at the legal text.

The NGESO representative clarified that in relation to slide 11 that below 50% is a priority for reactive current injection and above 50% there should be a minimum requirement to supply reactive current with any residual being supplied as active current. It was agreed that it needs to be clarified which of these are the priority and this needs to be clearly articulated. A Workgroup member queried whether there needed to be an example around where the voltage drops below 50%. The NGESO representative stated that where the voltage drops below 50% the reactive current should be prioritised.

A Workgroup member queried whether the proposal was asking for absolute levels of current. The NGESO representative stated that he would review whether these are absolute values or delta values.

A Workgroup member raised in relation to ECC.6.3.16.1.4 that if this is a requirement, then this should be in the compliance section of the Grid Code as opposed to the European Connection Code. The NGESO representative agreed to discuss this with the National Grid Compliance Team before updating the legal text.

A Workgroup member queried where the items specified in Article 20 are reflected in the draft legal text? The NGESO representative stated that as part of the mapping exercise that was completed as part of the GC0100 consultation.

The NGESO representative confirmed that he would take the Workgroup feedback on board, amend the legal text and recirculate it around the Workgroup for comment. Part of this analysis would be to ensure there is consistency between the proposed legal text and the European Connection Codes.

#### Workgroup 3 – 7 November 2018

A presentation was presented by the National Grid Electricity System Operator (NGESO) representative to the Workgroup which is attached in Annex 2C.

Following discussions and emails in between the Workgroups, the NGESO representative drafted and presented to the Workgroup two versions of the legal text – 1A and 1B. As noted above version 1A was based on the draft text discussed at the September meeting and version 1B incorporates elements from the fast fault current injection requirements of EN50549.

A Workgroup member stated that they would suggest not using pre-fault in the formula on slide 7 of the slide pack. In addition, some practical examples would be helpful to understand the requirements better.

A Workgroup member observed that the changes to voltage would have a minimal impact on Distribution Network Operators.

In relation to the legal text – version 1A, the NGESO representative stated that the diagram on slide 10 is in relation to the sum of all the turbines.

In relation to legal text – version 1B, the NGESO representative stated that incorporating EN50549 means that it becomes very complex very quickly. Based on discussions prior to the Workgroup, the NGESO representative stated that it seemed that the majority of

the Workgroup were in favour of legal text -version 1A although it was recognised that it needed further work including agreeing a recommendation for implementation. Legal text 1A will result in minimal impact on the industry when devising the solution.

A workgroup member queried whether the EN50549 requirements link to HVDC equipment and queried whether any Workgroup members manufacture that kind of equipment to ensure their view is reflected. The NGESO representative confirmed that this did relate to HDVC Equipment and that there are Workgroup members from Siemens who manufacture HVDC equipment.

The Workgroup unanimously agreed that the Workgroup should proceed with version 1A of the legal text for the solution.

The Workgroup reviewed the legal text by exception to allow the legal text to be further developed.

A Workgroup discussed the timeline, and agreed that they wanted to talk through some worked examples before deciding whether to proceed to a Workgroup consultation.

The Workgroup discussed the terms of reference set by the Grid Code Review Panel:

a. Implementation and costs

In terms of costs, the NGESO representative stated that the implementation will be linked to contracts and that the aim is to minimise any costs as the changes to the legal text are for clarification purposes only and should not result in additional cost.

b. Develop draft the legal text

This is currently in progress and will be completed to be submitted with the Workgroup Report to the Grid Code Review Panel.

c. Consider whether any further industry experts or stakeholders should be invited to participate in the Workgroup

This has been done on an ongoing basis. The Workgroup is comprised of industry experts. The NGESO representative expressed his gratitude for the participation and help given so far in developing the solution.

d. Consider the materiality of the change

The materiality of the change is low as the purpose of the modification is to provide clarity to industry.

e. Requirement for a Workgroup Consultation

This is unknown until the Workgroup has seen some worked examples. At that point the Workgroup can decide whether to proceed to a Workgroup consultation.

f. Review the trigger voltage and Fault Ride Through requirements and whether the changes are compatible

The NGESO representative stated that this is a National Grid issue and he believes this is minimal. He will continue to consider this as the solution is developed.

One Workgroup member provided a spreadsheet showing plant performance, which was circulated to the Workgroup.

Workgroup 4 – 6 December 2018

A presentation was presented by the National Grid Electricity System Operator (NGESO) representative to the Workgroup which is attached in Annex 2D.

The NGESO representative presented to the Workgroup a presentation which included a number of worked examples to demonstrate how the proposed solution would work in practice.

The Workgroup discussed compliance and agreed there needed to be section on compliance legal text included in the solution to complete the modification.

A Workgroup member queried whether there was a need for a further compliance modification as there are a number of issues that needed to be addressed.

The Workgroup agreed to continue to use the term “insensitivity” as opposed to dead band to provide greater clarity to Grid Code users.

A Workgroup member queried when the 20 milliseconds in example 5 starts. It was agreed that NGESO would look at this.

The Workgroup discussed the formula in example 2 of the slide pack (see Appendix 1D) and it was agreed that the NGESO representative would review the formula and re-circulate this around the Workgroup.

On slide 36, The NGESO representative stated that based on the approach set out in slide 36, it is possible to calculate the FFCI Power Park Module performance requirement at the connection point and work back to each turbine.

In terms of the implementation, it was agreed by the Workgroup that the approach should be that it runs from the signing of the contract rather than the completion date of plant installation though care needed to be exercised as the current Grid Code drafting is not that clear.

A workgroup member asked for the implementation to be clearly set out including how long it will take manufacturers to implement this modification.

There is a requirement to update the PGMG to reflect the proposed changes.

Based on the worked examples, the Workgroup agreed that a Workgroup consultation was not necessary or required to develop the solution.

Workgroup 5 – 7 February 2019

[insert Workgroup Discussion]

Presentation - Annex 2E

## 5 Workgroup Vote

The Workgroup believe that the Terms of Reference have been fulfilled and GC0111 has been fully considered.

The Workgroup met on [insert date] 2019 and voted on whether the Original would better facilitate the Applicable Grid Code Objectives than the baseline and what option was best overall.

The Workgroup agreed [unanimously/by a majority of x] that the Original was better than the baseline. The voting record is detailed below.

The Workgroup voted against the Grid Code objectives for the Original Proposal. The Workgroup voted and [x] Workgroup members concluded that the Original Proposal is the best option and the baseline received [x] votes.

In conclusion, the Workgroup supported the [x] as the best option.

The voting record is detailed below:

### **Vote 1 – does the original facilitate the objectives better than the Baseline?**

#### **Vote recording guidelines:**

“Y” = Yes

“N” = No

“-” = Neutral

Workgroup Member	Better facilitates AGCO (i)	Better facilitates AGCO (ii)?	Better facilitates AGCO (iii)?	Better facilitates AGCO (vi)?	Better facilitates AGCO (v)?	Overall (Y/N)
Mike Kay (Proposer)						
Original						
Voting Statement:						
xx						
Tony Johnson						
Original						
Voting Statement:						
Xx						
Isaac Gutierrez						
Original						
Voting Statement:						
Xx						
Alastair Frew						
Original						
Voting Statement:						
xx						
Sridhar Sahukari						
Original						
Voting Statement:						
xx						

Garth Graham						
Original						
<b>Voting Statement:</b>						
xx						
Sigrid Bolik						
Original						
<b>Voting Statement:</b>						
xx						
Federico Rueda Londono						
Original						
<b>Voting Statement:</b>						
xx						
Marko Grizelj						
Original						
<b>Voting Statement:</b>						
xx						
Ireneusz Grzegorz Szczesny						
Original						
<b>Voting Statement:</b>						
xx						
Chandu Bapatu						
Original						
<b>Voting Statement:</b>						
xx						
Vicenç Casadevall						



Original						
<b>Voting Statement:</b>  xx						

**Vote 2 – Which option is the best? (Baseline, Original solution or WACM(s))**

Workgroup Member	BEST Option?
Mike Kay	
Tony Johnson	
Isaac Gutierrez	
Alastair Frew	
Sridhar Sahukari	
Garth Graham	
Sigrid Bolik	
Federico Rueda Londono	
Marko Grizelj	
Ireneusz Grzegorz Szczesny	
Chandu Bapatu	
Vicenç Casadevall	

## 6 GC0111: Relevant Objectives

Below set out how the Proposal meets the Applicable Grid Code Objectives as stated by the Proposer:

### Impact of the modification on the Applicable Grid Code Objectives:

Relevant Objective	Identified impact
(a) To permit the development, maintenance and operation of an efficient, coordinated and economical system for the transmission of electricity	Positive
(b) Facilitating effective competition in the generation and supply of electricity (and without limiting the foregoing, to	Positive

facilitate the national electricity transmission system being made available to persons authorised to supply or generate electricity on terms which neither prevent nor restrict competition in the supply or generation of electricity);	
(c) Subject to sub-paragraphs (i) and (ii), to promote the security and efficiency of the electricity generation, transmission and distribution systems in the national electricity transmission system operator area taken as a whole;	Neutral
(d) To efficiently discharge the obligations imposed upon the licensee by this license and to comply with the Electricity Regulation and any relevant legally binding decisions of the European Commission and/or the Agency; and	Positive
(e) To promote efficiency in the implementation and administration of the Grid Code arrangements	Neutral

#### Proposer's initial view:

The view of the Proposer is that GC0111 should be implemented without delay so that manufacturers gearing up for producing compliant equipment by the May 2019 deadline are in no doubt about the necessary performance requirements.

## 7 Implementation

The current Grid Code is considered unclear in its treatment of fast fault current injection. As this change is deemed as clarification the Proposer seeks views from the Workgroup as to whether this approach is considered reasonable or whether a future implementation date is proposed on the basis that the revised requirements are quite complex to achieve.

## 8 Legal Text

Annex 3 details the proposed changes to the European Connection Code and European Compliance Processes should GC0111 be approved and implemented.

## Annex 1 – Terms of Reference

X

## Annex 2A – Workgroup Presentation July 2018

x

## Annex 2B – Workgroup Presentation September 2018

x

## Annex 2C – Workgroup Presentation November 2018

## Annex 2D – Workgroup Presentation December 2018

## Annex 2E – Workgroup Presentation February 2019



## Annex 3 – Legal Text