Grid Code Workgroup Consultation Response Proforma

GC0130 – OC2 Change for simplifying 'output useable' data submission and utilising REMIT data

Industry parties are invited to respond to this consultation expressing their views and supplying the rationale for those views, particularly in respect of any specific questions detailed below.

Please send your responses by **5pm** on **23 December 2019** to <u>grid.code@nationalgrid.com</u>. Please note that any responses received after the deadline or sent to a different email address may not receive due consideration by the Workgroup.

Respondent:	Peter Berry	
	01633 530135	
Company Name:	Calon Energy Group Limited (Incorporating Severn Power	
	Generation Limited; Baglan Operations Limited; Sutton Bridge	
	Power Generation)	
Please express your views Overall this is a sensible modification proposal to remove		
regarding the Workgroup	to entry and costs for smaller generators. For ourselves, this	
Consultation, including	change will remove duplication of effort and the need to maintain	
rationale.	two systems. With the current TOGA system coming to the end	
(Please include any issues, suggestions or queries)	of its life, this change was inevitable. Aligning output data with REIMT makes sense and will reduce effort should Brexit have any impacts to data reporting in the UK.	

Standard Workgroup Consultation questions

Q	Question	Response
1	Do you believe that GC0130 Original proposal, the proposed alternative in Annex xx or any	For reference the applicable Grid Code objectives are:
	potential alternative that you may wish to suggest better facilitates the Grid Code Objectives?	<i>(i) to permit the development, maintenance and operation of an efficient, coordinated and economical system for the transmission of electricity;</i>
		(ii) to facilitate competition in the generation and supply of electricity (and without limiting the foregoing, to facilitate the national electricity transmission system being made available to persons authorised to supply or generate electricity on terms which neither prevent nor restrict

		competition in the supply or generation of electricity);
		(iii) subject to sub-paragraphs (i) and (ii), to promote the security and efficiency of the electricity generation, transmission and distribution systems in the national electricity transmission system operator area taken as a whole;
		(iv) to efficiently discharge the obligations imposed upon the licensee by this license and to comply with the Electricity Regulation and any relevant legally binding decisions of the European Commission and/or the Agency; and
		(v) To promote efficiency in the implementation and administration of the Grid Code arrangements.
		No – we are happy with the proposed 'new' solution whereby either TOGA or OC2
2	Do you support the proposed implementation approach?	We do accept the proposed implementation in so far that this modification is to deal with the grid code changes required and a separate change will manage the technical changes. More details on the IT impacts at this stage would be useful.
3	Do you have any other comments?	No
4	Do you wish to raise a WG Consultation Alternative Request for the Workgroup to consider?	No

Specific GC0130 questions

Q	Question	Response
5	Which system do you think you	REMIT
	would use for your data	
	submission, i.e. TOGA, Remit or	
	both if given the choice?	
6	We will define in the Grid Code	1 Hour seems practical and in line with our
	that each generator shall provide	current approach of submitting output changes
	The Company with any changes	via the REMIT platform (e.g. Outages)
	to the available Output Usable	
	from now until 3 years ahead. We	
	propose for an unplanned Event,	
	the Generator shall provide the	
	data within 1 hour of the event	

	occurring, and for a planned Event, the Generator shall provide the data within 1 hour of the planning of the Event. This in REMIT is within 5 minutes, so:	
	For non-REMIT submissions (direct to TOGA), on a known change of output, within what timeframe do you think these changes should be notified to National Grid ESO (where 1 hour is the example above)?	
7	Does the use of the REMIT description field for multi-shaft data cause any existing Users any problems?	No, this does not currently cause any issue. Sutton Bridge has two GT's. The use of the SONAR fax however does cause issues.
8	Can you confirm that you are happy for the removal of margin zonal data, if you are not, please explain the issue?	Yes – we no longer use this zonal data
9	Can you indicate the amount of time you would require to prepare for the change in how data is submitted to NGESO where applicable?	3 months (minimum) lead time to ensure we can impact assess the changes and make the necessary amendments to systems and processes.