

WELCOME

GC0155

Clarification of Fault Ride Through Technical Requirements

Meeting 1

10 February 2022

Online Meeting via Teams

nationalgridESO



Modification Process

Banke John-Okwesa – National Grid ESO Code Administrator

Code Modification Process Overview



Talk to us

Forums



Raise a
mod

Panels



Refine
solution

Workgroups
(Workgroup Consultations)



Consult



Decision

Ofgem/Panel



Implement



Refine solution Workgroups



- If the proposed solution requires further input from industry in order to develop the solution, a Workgroup will be set up.
- The Workgroup will:
 - further refine the solution, in their discussions and by holding a **Workgroup Consultation**
 - Consider other solutions, and may raise **Alternative Modifications** to be considered alongside the Original Modification
 - Have a **Workgroup Vote** so views of the Workgroup members can be expressed in the Workgroup Report which is presented to Panel



Consult

Code Administrator Consultation

- The Code Administrator runs a consultation on the **final solution(s)**, to gather final views from industry before a decision is made on the modification.
- After this, the modification report is voted on by Panel who also give their views on the solution.





Decision



- Dependent on the Governance Route that was decided by Panel when the modification was raised
- **Standard Governance:** Ofgem makes the decision on whether or not the modification is implemented
- **Self-Governance:** Panel makes the decision on whether or not the modification is implemented
 - an appeals window is opened for 15 days following the Final Self Governance Modification Report being published



Implement

- The Code Administrator implements the final change which was decided by the Panel / Ofgem on the agreed date.



The slide features several decorative yellow lines. In the top left, there are several thin, curved lines that sweep across the upper portion of the slide. In the bottom right, there are three thick, parallel diagonal lines that extend from the bottom left towards the top right. Additionally, a single thick yellow line runs horizontally across the bottom of the slide, just above the logo.

Workgroup Responsibilities

Banke John-Okwesa – National Grid ESO Code Administrator

Expectations of a Workgroup Member

Contribute to the discussion

Be respectful of each other's opinions

Language and Conduct to be consistent with the values of equality and diversity

Do not share commercially sensitive information

Be prepared - Review Papers and Reports ahead of meetings

Complete actions in a timely manner

Keep to agreed scope

Your Roles

Help refine/develop the solution(s)

Bring forward alternatives as early as possible

Vote on whether or not to proceed with requests for Alternatives

Vote on whether the solution(s) better facilitate the Code Objectives

The background of the slide features several decorative yellow lines. In the top left, there are several thin, curved lines that sweep across the upper portion of the slide. In the bottom right, there are several thicker, parallel diagonal lines that extend from the bottom left towards the top right, creating a sense of movement and direction.

Workgroup Alternatives and Workgroup Vote

Banke John-Okwesa – National Grid ESO Code Administrator

Can I vote? and What is the Alternative Vote?

To participate in any votes, Workgroup members need to have attended at least 50% of meetings

Stage 1 – Alternative Vote

- Vote on whether Workgroup Alternative Requests should become Workgroup Alternative CUSC Modifications.
- The Alternative vote is carried out to identify the level of Workgroup support there is for any potential alternative options that have been brought forward by either any member of the Workgroup OR an Industry Participant as part of the Workgroup Consultation.
- **Should the majority of the Workgroup OR the Chair believe that the potential alternative solution may better facilitate the CUSC objectives than the Original then the potential alternative will be fully developed by the Workgroup with legal text to form a Workgroup Alternative CUSC modification (WACM) and submitted to the Panel and Authority alongside the Original solution for the Panel Recommendation vote and the Authority decision.**

Can I vote? and What is the Workgroup Vote?

To participate in any votes, Workgroup members need to have attended at least 50% of meetings

Stage 2 – Workgroup Vote

- 2a) Assess the original and WACMs (if there are any) against the CUSC objectives compared to the baseline (the current CUSC)
- 2b) Vote on which of the options is best.



Timeline

Banke John-Okwesa – National Grid ESO Code Administrator

Timeline for GC0155

Milestone	Date	Milestone	Date
Proposal Presented to Panel	16 December 2021	Panel undertake DFMR recommendation vote	28 July 2022
Workgroup 1 – (discussion of the proposal) and solution, agree timeline and review terms of reference	10 February 2022	Final Modification Report issued to Panel to check votes recorded correctly (5 working days)	01 August 2022 – 08 August 2022
Workgroup 2 (finalise solution to be consulted on, agree alternatives and agree Workgroup Consultation questions)	10 March 2022	Final Modification Report issued to Ofgem	09 August 2022
Workgroup Consultation (15 Working Days)	21 March 2022 – 11 April 2022	Ofgem decision	TBC
Workgroup 3 (Post Workgroup Consultation - Assess Work group consultation responses)	26 April 2022	Implementation Date	10 working days after Ofgem decision
Workgroup 4 Finalise solution(s) and legal text, agree that Terms of Reference have been met, Review Workgroup Report and hold Workgroup Vote	10 May 2022		
Workgroup Report issued to Panel (5 working days)	18 May 2022		
Panel sign off that Workgroup Report has met its Terms of Reference	26 May 2022		
Code Administrator Consultation	01 June 2022 – 30 June 2022		
Draft Final Modification Report (DFMR) issued to Panel	20 July 2022		

Proposer's Solution:

Terry Baldwin – National Grid ESO

Background

This modification proposal is based on an alternative proposal (WAGCM2) to **GC0151** '*Grid Code Compliance with Fault Ride Through Requirements*' by Drax Power Ltd. It seeks to clarify the technical requirements for fault ride through capability set out in the Grid Code to improve consistency, accuracy and understanding and to help prevent non-compliance with the Grid Code.

Clarification of Fault Ride Through Requirements

Issue-

The way CC.6.3.15(a)(i) is written deals both with plant capability and actions to be taken during a fault, however, it does not clearly distinguish between either leading to confusion.

Proposed solution-

It is suggested that the current CC.6.3.15(a)(i) is split into two sections, one dealing with the required capability CC.6.3.15(a)(i)(a) and a second section CC.6.3.15(a)(i)(b) dealing with actions to be taken during a fault.

Plant Capabilities

Proposed solution-

The new section CC.6.3.15(a)(i)(a) will only deal with plant capabilities by clarifying that the plant has to be capable of riding through the worst fault that the network could impose which is a 3-phase short circuit at the connection point which lasts for up to 140ms.

Proposed Legal text

The words “be design to” will be added to section CC.6.3.15(a)(i)(a) as can be seen in the legal text in appendix 1.

Operating Requirements During a Fault

Issue-

The new section CC.6.3.15(a)(i)(b) will specify the actions to be taken if a fault occurs by requiring that plants ride through faults in the transmission system which can be cleared by the transmission system circuit breaker as shown in figure 2 below and by adding the following text as the introduction to the section

Proposed Legal text

- (b) Each **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and **OTSDUW Plant and Apparatus** shall remain transiently stable and connected to the **System** without tripping of any **Generating Unit, DC Converter or Power Park Module** and / or any constituent **Power Park Unit, OTSDUW Plant and Apparatus**, and for **Plant and Apparatus** installed on or after 1 December 2017, reactive compensation equipment, for any balanced and unbalanced fault where subjected to a voltage dip at either the **Onshore Grid Entry Point** or **Interface Point** as applicable where the voltage remains either on or within the envelope shown in figure CC.6.3.15(a)(i)(a) except where:

Operating Requirements During a Fault




Figure 2 showing a fault which can be cleared by transmission system breakers TCB3 & 4

Operating Requirements During a Fault

Issue-

Whilst the introduction deals with plants riding through faults as it is currently drafted in the Grid Code, it is not clear what is supposed to happen where the plant's circuit breaker has to open to clear the fault.

There are concerns that the current text could be interpreted that the plant shall remain connected feeding the fault for 140ms which could lead to dangerous situations. It is clear this is not the intent, and that plant should trip during these circumstances.

It is proposed that the following subclauses are added to clarify each situation where tripping is permitted.

Subclause 1

If the fault is on the Generator's equipment then the Generator shall be required to trip to clear the fault from the transmission system as detailed in the proposed new section CC.6.3.15(a)(ii)(b)(i) (note that this is already permitted in the ECCs), as follows:-

Power Park Module and any constituent **Power Park Unit** thereof and **OTSDUW Plant and Apparatus** shall trip to clear the fault from the **Transmission System**. The protection schemes and settings should not jeopardise **Fault Ride Through** performance as specified in CC.6.3.15.1




Figure 3 showing a fault which can only be cleared by generator breakers GCB1

Subclause 2

If the location of the fault on the network that means that the fault can only be cleared by operation of both Transmission and the Generator circuit breaker as shown in figure 4, again the Generator will be permitted to trip to clear the fault as detailed in the proposed new section CC.6.3.15(a)(i)(b)(ii) and ECC.6.3.15.8(vi)(i), as follows:-

the location of the fault means it cannot be fully cleared without tripping the of **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and the **OTSDUW Plant** shall trip as required.




Figure 4 showing a fault which can only be cleared by generator breaker GCB1 & transmission circuit breaker TCB1

Subclause 3

if the location of the fault on the network means that the Generator will become islanded by the operation of the transmission circuit breakers as shown in figure 5 then it shall be permitted to trip as detailed in the proposed new sections CC.6.3.15(a)(ii)(b)(iii) and ECC.6.3.15.8(vi)(ii), as follows:-

clearance of the fault results in the **Generating Unit, DC Converter, or Power Park Module or OTSDUW Plant** becoming islanded and disconnected from the **Total System** and not supplying **Customers** (where CC.6.3.7(c)(i) applies), then the **Generating Unit, DC Converter, or OTSDUW Plants** shall be permitted to trip as required.




Figure 5 showing a fault which can be cleared by transmission breakers TCB1,2&3, however this results in the Generator being islanded from the main transmission system and needs to come off

Subclause 3

Also, if there are inter-trip arrangements with the TO or ESO in relation to protection schemes to prevent cascade overloading, etc then plants shall be required to trip as per these arrangements as detailed in the proposed new section CC.6.3.15(a)(i)(b)(iv & v) and ECC.6.3.15.8(iii & iv), as follows:-

the **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and **OTSDUW Plant** is part of combined protection scheme with the **Transmission Operator**, then the **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and **OTSDUW Plants** shall be permitted to trip as required.

the **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and **OTSDUW Plant** is part of and intertrip scheme which is switched into service and triggered, then the **Generating Unit, DC Converter, or Power Park Module** and any constituent **Power Park Unit** thereof and **OTSDUW Plants** shall be permitted to trip as required.

Fault Current Injection

Issue-

The area of the current legal text which technically creates the biggest problem in relation to compliance are in sections CC.6.3.15 (a)(ii) and ECC.6.3.15.9.2.1(a)(i) which currently state “for which the voltage at the Grid Entry Point (or Interface Point in the case of OTSDUW Plant and Apparatus) is outside the limits specified in CC.6.1.4, each Generating Unit or Power Park Module or OTSDUW Plant and Apparatus shall generate maximum reactive current”. If this requirement is drawn out on the figure 6 below where the current and voltage must always either be within the green shaded area or on the red line.




Figure 6 showing an interpretation of the existing legal text requiring the current to either be in the green box or on the red line

Fault Current Injection

Proposed Legal text

- (iv) During the period of the fault as detailed in CC.6.3.15.1 (a) (i) for which the voltage at the **Grid Entry Point** (or **Interface Point** in the case of **OTSDUW Plant and Apparatus**) is outside the limits specified in CC.6.1.4, each **Generating Unit** or **Power Park Module** or **OTSDUW Plant and Apparatus** shall inject a reactive current above the heavy black line shown in Figure CC.6.3.15(b) without exceeding the transient rating limit of the **Generating Unit, OTSDUW Plant and Apparatus** or **Power Park Module** and / or any constituent **Power Park Unit** or reactive compensation equipment.




Figure 7 showing the proposed reactive current injection requirements, requiring the current to always remain above the black line

Active Power Requirements- (solution required)

Issue-

Minimum active Power requirements after the fault has cleared because within CC.6.3.15.1 a) ii) it states:

(or within 0.5 seconds of restoration of the voltage at the **User System Entry Point** to 90% of nominal or greater if **Embedded**), Active Power output or in the case of OTSDUW Plant and Apparatus, Active Power transfer capability, shall be restored to at least 90% of the level available immediately before the fault. Once the Active Power output, or in the case of OTSDUW Plant and Apparatus, Active Power transfer capability, has been restored to the required level, Active Power oscillations shall be acceptable provided that:

- the total Active Energy delivered during the period of the oscillations is at least that which would have been delivered if the Active Power was constant
- the oscillations are adequately damped

Whilst this works in principle at higher loads, it does create an issue at lower loads if you consider a real event for a unit operating as a synchronous condenser in figure 8.

Active Power Requirements




Figure 8 showing a typical active power response of a unit at low load to a fault

If you look at the initial load which is 0.02 pu then 90% of this small number you get a very small number, it is also difficult to see how a sensible compliance assessment can be carried out at these levels and it is hence suggested that under these circumstances the tolerance should be changed.

Voltage Protection Settings

Issue-

The Grid Code defines in detail the FRT requirements for voltage dips, it is silent on the requirement for Users or Network Operators to remain connected for transient over-voltages, particularly those that are expected to occur after the clearance of a fault.

Therefore it is possible, for example, that currently a Generator or Interconnector may successfully ride through a voltage dip, but trip when the fault is cleared as the resulting over-voltage transient is sufficiently high or sustained that it could trigger over-voltage protection that would ordinarily be expected to be fitted by the User (or Network Operator) to protect their equipment.

It is also possible a User site or Network Operator asset could ride through a low voltage fault but incorrectly configured protection settings result in the User site or Network Operator asset(s) tripping or de-loading.

Voltage Protection Settings

Proposed solution-

To provide further clarity to Users and Network Operators, it is proposed that wording along the following lines would be added to Section CC.6.3.15.3 and ECC.6.3.15.10 ('Other Fault Ride Through Requirements'):

- Users and Network Operators shall ensure voltage sensitive relays installed to protect the User's plant and / or apparatus or Network Operator's asset are configured such that they will not prevent correct operation of the Fault-Ride-Through capability of the User's equipment (or Network Operator's assets) against the relevant Voltage-Time curves. For example,
 - o Over-voltage protection shall be configured to be insensitive to transient overvoltages of at least 1.20pu for at least 0.5 seconds.
 - o Under-voltage protection shall be configured to be insensitive for transient undervoltages of below 0.8pu for at least 3 seconds



Terms of Reference

Banke John-Okwesa – National Grid ESO Code Administrator

GC0155 – Terms of Reference

Workgroup Term of Reference	Location in Workgroup Report
a) Implementation and costs;	
b) Review draft legal text should it have been provided. If legal text is not submitted within the Grid Code Modification Proposal the Workgroup should be instructed to assist in the developing of the legal text; and	
c) Consider whether any further Industry experts or stakeholders should be invited to participate within the Workgroup to ensure that all potentially affected stakeholders have the opportunity to be represented in the Workgroup. Demonstrate what has been done to cover this clearly in the report	
d) Consider EBGL implications	
e) Minor changes and clarifications to the existing Grid Code Fault Ride Through (FRT) requirements specifically but not limited to consideration of the following areas: i. Clarify instances where User plant is required to trip in order to clear transmission system faults ii. Amending requirements for generating maximum reactive current during faults where these may be unachievable for some generators iii. Amending post-fault active power requirements to consider whether generators at low load may have greater levels of oscillation than permitted iv. To consider clarifying and or defining requirements for over-voltage during a fault	
f) Consider and address any cross code impacts on other codes especially Distribution Code (e.g. G99 requirements)	

Next Steps

Banke John-Okwesa – National Grid ESO Code Administrator

- Review Actions
- Review Legal Text
- Workgroup Consultation Questions