

Grid Code Review Panel – September 2008

Summary of Actions and Status

<u>Minute No.</u>	<u>Item</u>	<u>Owner</u>	<u>Status</u>
800	Basic Electrical Safety Competence (BESC) - National Grid are reviewing the applicability for BESC certification for external parties requiring access to National Grid substations. National Grid will keep the Panel informed of progress on this issue.	National Grid	Ongoing
839	Planning Data - PC4.4.2 - National Grid to undertake a review of the 28 day period in PC4.4.2 for provision of detailed planning data with the proposed connection date.	National Grid	Ongoing
847	Protection Issues - Insufficient redundancy between National Grid's and the Generator's protection systems where the two Main protections and one back up system has been installed on the Generator's system. National Grid to put forward proposed transitional arrangements at a future GCRP meeting.	National Grid	Agenda
889	Grid Code Structure - National Grid was discussing a more User-friendly version of the Grid Code with the Plain English Campaign. Elexon to share their experience with the BSC in this area with National Grid.	Elexon	Completed
900	Outstanding Issues List - National Grid to investigate the position on delegation of authority for busbar switching contracts and report back to the May GCRP.	National Grid	Update
945	System to Generator Operational Intertipping Schemes - National Grid would go out to consultation after comments from JN and DW taken into account.	National Grid	Update
943	Forecast Output for Embedded Generation in Scotland less than 100MW - Resolve outstanding issues with Panel Members before consultation issued.	National Grid	Update
947	Grid Code Requirements for Power Park Modules Voltage Control and Reactive Power Capability - Panel agreed that should proceed to consultation	National Grid	Completed
949	Compliance Technical Performance - Panel agreed proceed to consultation subject to resolution of issues with DW	National Grid	Completed

<u>Minute No.</u>	<u>Item</u>	<u>Owner</u>	<u>Status</u>
954	Data Exchange Working Group Report - Panel agreed proceed to consultation	National Grid	Completed
955	Rated MW - Report back to the September GCRP with an interim solution. Enduring solution to be remitted to new joint GCRP/CUSC Working Group on reactive power	National Grid	Agenda
961	Small Embedded Generation Loss Risk on System High Frequency Excursions - Outstanding information from 4 DNOs requested by the end of June	MK & AC	Agenda
969	Grid Code Compliance Capability for New Technologies - bring forward a proposal to the September GCRP to overcome the SCR restriction - Establish a joint GCRP/CUSC Working Group on Frequency Response to pursue outstanding issues - Establish a joint GCRP/CUSC Working Group on reactive power to pursue outstanding issues - Keep under review issues associated with islanding performance, synthetic inertia and power oscillation damping	National Grid National Grid National Grid National Grid	Agenda Completed Ongoing Ongoing
974	LEEMPS Operational Metering - BT to check if system could accommodate a variety of protocols - BV to provide paper to AEP Members and report feedback	National Grid & BV	Ongoing Ongoing
976	Multi-Unit BMUs Update - GCRP Members to provide comments to BT - BT to report the overall outcome by e-mail	GCRP Members National Grid	Ongoing Ongoing
978	GB Transmission System Study Network Data File - Provide comments to BT - BT to feedback to the Panel by e-mail	GCRP Members National Grid	Completed Agenda
979	Offshore Transmission - GCRP Members to provide feedback to Ofgem on structure of workshop	GCRP Members	Completed
982	Authority Decision on CAP149 – TEC Lite - Consider consequential Changes to the Grid Code arising from this Decision	National Grid	Agenda
985	CUSC Cross-Codes Standing Group on Environmental Issues - GCRP Members to put forward nominations for Membership	GCRP Members	Completed

<u>Minute No.</u>	<u>Item</u>	<u>Owner</u>	<u>Status</u>
986	Electricity Generation from Gas Networks (Blue LNG) - National Grid to report back to the September GCRP on any implications for the Grid Code	National Grid	Ongoing
988	Delegations of Authority for Busbar Switching Contracts - National Grid to provide further progress report	National Grid	Ongoing