

FaVOR Consultation Responses

November 2010 GCRP Update

Working Group Conclusions

- Working Group Report and recommendations published:
 - Clarify Voltage Requirements
 - Introduce time limited frequency bands
 - 51.5 Hz – 52 Hz > 15 mins operation
 - 51 Hz – 51.5 Hz > 90 mins
 - 48.5Hz – 51 Hz Continuous operation
 - 47.5 Hz – 48.5Hz > 90 mins
 - 47 Hz – 47.5 Hz > 20 Sec
 - Some members believed a lower continuous operation limit at 49.0Hz is better aligned with IEC standards
 - NGET did not conclude that system security would not be impacted and the first stage of the LFDD scheme

Consultation

- Consultation put forward two options on frequency range
 - Option 1: based around 48.5Hz
 - Option 2: based on 49.0Hz
- Five responses received
 - Supportive of the proposals
 - Four respondents expressed a preference for Option 2