


# Geomagnetic Disturbances Grid Code Review Panel 21 November 2012



Andrew Richards  
Severe Risk Analyst  
National Grid


# Coronal Mass Ejection

---



# Solar Cycles


- Sun follows a cycle, roughly 11 years
- Number of sunspots indicates how much activity
- Cycle 24 will reach maximum in March 2013
- 2 to 3 years after maximum most active for solar storms
- Cycle 24 was predicted to be weakest for 100 years
- It's turned out even weaker than predicted



## Effects on the system

---

- Magnetic flux leakage from core
  - Overheating, gassing, shutdown
    - Potentially catastrophic failure
- Distorted output waveform
  - Higher harmonics present
  - Protective relays triggered
  - Control assets switched out
- Increased reactive power consumption
  - Voltage instability



## Risk Factors


---

- Geographic Location
  - Further north
  - Geological structure – down to 500km
- Line length
- Line resistance
- Last two explain why no disturbance ever observed in low voltage network

# Sunspots

---


- 18 October 2003



## Sunspots

---


- 19 October 2003



## Sunspots

---

- 20 October 2003






## Sunspots

---


- 21 October 2003



## Sunspots

---


- 22 October 2003



# Sunspots

---


- 23 October 2003



# Sunspots

---


- 24 October 2003



# Sunspots

---


- 25 October 2003



# Sunspots

---


- 26 October 2003



# Sunspots

---


- 27 October 2003



## Sunspots


---

- 28 October 2003





## X-Ray burst from solar flare



Updated 2011 Feb 15 23:55:12 UTC


NOAA/SWPC Boulder, CO USA

# ENLIL Model


2012-05-13T00:00

2012-05-13T00 +0.00 day

● Earth



## CME arrival at ACE



## Warning actions

---

- Day -4 onward
  - Monitor all available space weather sources carefully
- Day -1 Observe CME
  - Issue warning of possible system disturbance
- At T -15 minutes
  - Observe direction of Bz at ACE
  - Reissue warning of system disturbance

## NG Operational Mitigation

---

### ■ ALL IN:

- All circuits returned to service and switched in
- All Supergrid Transformers connected
- Substations run solid
- Extra generation instructed to synchronise
- Extra reactive support made available
- All monitoring and warning systems utilised

## Notice of System Disturbance

---

- The same as any System Disturbance warning for any other cause
  - Flood, storm, lightning.....
- Continue to follow PNs
- Contribute to system integrity
- Market continues to operate unless.....
- National Grid may issue Emergency Instructions to depart from normal Balancing Market Operations in accordance with BC2.9
- Acceptance of an Emergency Instruction counts as acceptance of Bid-Offer Acceptance

## Modelling work for E3C


---

- Focuses on risk of physical damage to high voltage transformers
- Gives order of magnitude results for a couple of extreme (1 in 100 year) scenarios
- Work requested by E3C includes generator transformers in network model
- Can provide risk to individual transformers at different GIC levels
- Can't be used to identify transformers at risk in any GMD – GIC levels too dependent on individual storm

# National Grid / BGS MAGIC Webtool


## Magnetometer records

nationalgrid






# National Grid / BGS MAGIC Webtool nationalgrid Network Model display



# GIC Monitoring



## Cooperation for Cycle 24



Lancaster University  
Manchester University  
Cardiff University



NOAA  
NASA  
NERC (UK)  
NERC (US)

National Grid UK  
(4 SUNBURST sensors)  
National Grid US  
(2 SUNBURST sensors)



Scottish Power  
DECC  
Cabinet Office