

Frequency Changes Workgroup: Post consultation proposals*

RoCoF § >5MW				
		Asynchronous	Synchronous	Medium Power Stations
Generators Commissioned before 01/04/14	<u>Settings permitted until 01/04/16</u>	<u>$K2 \times 0.125 \text{ Hz/s}^\#$</u> <u>or</u> <u>$1\text{Hz/s}^{\uparrow\#}$</u> <u>time delay 0.5s</u>	<u>$K2 \times 0.125 \text{ Hz/s}^\#$</u> <u>or</u> <u>$1\text{Hz/s}^{\uparrow\# \Omega}$</u> <u>time delay 0.5s</u>	<u>Intertipping Expected</u>
	<u>Settings permitted on or after 01/04/16</u>	<u>$1\text{Hz/s}^{\uparrow\#}$</u> <u>time delay 0.5s</u>	<u>$1\text{Hz/s}^{\uparrow\# \Omega}$</u> <u>time delay 0.5s</u>	<u>Intertipping expected</u>
Generators commissioned on or after 01/04/14		<u>$1\text{Hz/s}^{\uparrow\#}$</u> <u>time delay 0.5s</u>	<u>$1\text{Hz/s}^{\uparrow\# \Omega}$</u> <u>time delay 0.5s</u>	<u>Intertipping expected</u>
Generators commissioned on or after 01/04/16		<u>$1\text{Hz/s}^{\uparrow\#}$</u> <u>time delay 0.5s</u>	<u>$1\text{Hz/s}^{\uparrow\#}$</u> <u>time delay 0.5s</u>	<u>Intertipping expected</u>

*To be agreed by Workgroup