

Assigning Detailed Planning Data (DPD) references to DPD I or DPD II

Grid Code Review Panel

16 July 2014

Background

- Detailed Planning Data (DPD) submitted for technical design of new connections
- GC0008 (H/09) segregated required data into DPD I and DPD II
- DPD I – initial plan data; submitted within 28 days of connection acceptance
- DPD II – predominately detailed equipment specification; provided at least two years before completion

Changes

- A number occurrences of DPD without explicit reference to specific section still exist
- Changes to be made to provide consistency within applications and clarity to those submitting and reviewing connection applications
- Proposed changes are in line with how data is currently treated

Proposal

- GCRP are invited to progress the issue to Industry Consultation