

Date:


Monday 07 Feb 2022

BSUoS Charge Estimate: £6.15/MWh

Total Outturn: £8.82m





BM Cost (Indicative)

AS Cost (Estimate)



Daily Balancing Costs

nationalgridESO



Commentary

A short market over the morning to midday, and over the late afternoon to evening. Overnight Trades were required for Downward Regulation. Interconnector Trades were required for Margin between 6am and 8am, and from 4pm to 5pm.

Overnight Voltage Control supported by Trades and BM Action in the Midlands and South East of England. BM Action overnight for System Inertia. BM Action alleviated thermal export constraints in the North of Scotland from 10.30am onwards, continuing into the night, when BM Action was also required for thermal export constraints in the North of England.