

Requirements for Generators: Banding Setting Progress



RfG Latest

- Joint Grid Code/D-Code workgroup GC0048 has been meeting to progress implementation since early 2014
- Code text was adopted by EU Member States on 26th June 2015. It is expected to 'Enter Into Force' (EIF) in Q1/Q2 2016
- Code determines users as 'New' or 'Existing' depending on when they procure main plant items. From two years after EIF onwards, RfG applies (user is 'New')
- GC0048 are looking to conclude GB implementation in 12 months to maximise lead-time for manufacturers and developers to understand new requirements
- **Immediate priority is agreeing RfG banding levels** ²

Background #1

- Technical requirements in RfG are arranged into x4 **Types** based on a user's connection voltage and MW capacity
- Type A and B requirements are close to a **product standard**
- Type C and D requirements need **active generator management**
- Thresholds must be set on a national basis by the designated TSO, based on sound justification. This is then ratified by industry consultation and regulatory approval; a cost benefit analysis is **not** mandated
- **This process is ongoing in GC0048 at the moment!**

Maximum RfG banding levels permitted for GB:

Type	Connection Voltage	Capacity
A	< 110kV	800 W – 1 MW
B	< 110kV	1 MW – 50 MW
C	< 110kV	50 MW – 75 MW
D	> 110kV	75 MW +

Current GB Definitions:

Generator Size	SHET	SPT	NGET
Small	<10MW	<30MW	<50MW
Medium			50-100MW
Large	>10MW	>30MW	>100MW

Background #2

- Pertinent topics that follow on from setting the thresholds are:
 - New **Fault Ride Through** requirements which apply at Type B[†] and above
 - Mandatory **Frequency Response** for Type C and above[†]
 - National choice of **parameters** affecting all Types, where ranges are specified in RfG:
 - Voltage + Reactive Power
 - Frequency
 - Control + Protection
 - Process for new compliance testing and monitoring
- General conditions such as the criteria for new vs existing, processes for cost-benefit analysis and derogations also have to be done

Banding key points #1

- In RfG maximum/starting levels were drafted by ENTSO-E to be proportional to the size of each synchronous area
- GB values started lower than CE block, but were amended to be the same as these due to GB stakeholder pressure. They can be lowered if justified
- Three options considered and consulted on within the workgroup for GB:

Type	<u>Option 1 - High</u> Max GB levels	<u>Option 2 - Medium</u>	<u>Option 3 – Low</u> (Similar to Irish levels)
A	800W – 1MW	800W -1MW	800W – 1MW
B	1-50MW	1-30MW	1 – 5 MW
C	50-75MW	30-50MW	5 – 10MW
D	75MW	50MW+	10MW+

- Mid option was proposed by NGET, focused primarily on reducing the wide band of Type B (1-50MW) and achieving some more frequency response capability. Low option is close to Irish values, and continues theme of consistency to a neighbouring synchronous area
- All member states are currently considering reductions

Way Forward

- **Workgroup agreed to focus assessment of the ‘high’ option**
- Based on current predictions of generator connections little benefit in pushing for the medium position (only affects generators of 30-50MW capacity connecting at <132kV. Hardly any of these)
- Further engagement with Scottish TOs critical
- Grid Code legal text changes for banding will explicitly refer to a SO three-yearly review of the levels (as allowed by RfG)
- Imperative that no more time is spent debating banding – implementation timescales for Connection Codes very tight
- RfG bandings are not a panacea; lots of issues for SO managing existing sub-1MW generation which RfG bandings do not affect! NGET will consider solutions to managing this outside RfG

Any questions?

