Date	13/01 AM	13/01 PM	14/01 AM	14/01 PM	15/01 AM	15/01 PM	16/01 AM	16/01 PM	17/01 AM	17/01 PM	18/01 AM	18/01 PM	19/01 AM	19/01 PM	20/01 AM	20/01 PM	21/01 AM	21/01 PM	22/01 AM	22/01 PM	23/01 AM	23/01 PM	24/01 AM	24/01 PM	25/01 AM	25/01 PM	26/01 AM	26/01 PM	27/01 AM	27/01 PM	28/01 AM	28/01 PM
NRA away from risk of System Level NRAPM (Forecast Conditions)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
NRA away from risk of Scotland Level NRAPM (Forecast Conditions)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Week Number	1/2/19	8/9/19	15/9/19	22/9/19	1/7/19	8/9/19	15/9/19	22/9/19	1/10/19	1/12/19	1/3/19	1/4/19	1/5/19	1/6/19	1/7/19	1/8/19	1/9/19	1/10/19	1/11/19	1/12/19	1/13/19	1/14/19	1/15/19	1/16/19	1/17/19	1/18/19	1/19/19	1/20/19	1/21/19	1/22/19	1/23/19	1/24/19
	30/12/18	7/9/19	14/9/19	21/9/19	30/12/18	7/9/19	14/9/19	21/9/19	30/12/18	30/12/18	31/12/18	27/02/19	14/04/19	21/04/19	28/04/19	05/05/19	12/05/19	19/05/19	26/05/19	02/06/19	09/06/19	16/06/19	23/06/19	30/06/19	07/07/19	14/07/19	21/07/19	28/07/19	04/08/19	11/08/19	18/08/19
Wind Load Factor required to cause a System Level NRAPM	0.4	0.4	0.5	0.5	0.4	0.4	0.5	0.5	0.4	0.4	0.5	0.6	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Probability of seeing Wind load factor above	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Wind Load Factor required to cause a Scotland Level NRAPM	0.6	0.6	0.6	0.7	0.6	0.6	0.6	0.7	0.6	0.6	0.6	0.8	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
Probability of seeing Wind load factor above	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%

Week Number	25/8/19	1/9/19	8/9/19	15/9/19	22/9/19	29/9/19	6/10/19	13/10/19	20/10/19	27/10/19	3/11/19	10/11/19	17/11/19	24/11/19	1/12/19	8/12/19	15/12/19	22/12/19	29/12/19	5/01/20
	25/08/2019	01/09/2019	08/09/2019	15/09/2019	22/09/2019	29/09/2019	06/10/2019	13/10/2019	20/10/2019	27/10/2019	03/11/2019	10/11/2019	17/11/2019	24/11/2019	01/12/2019	08/12/2019	15/12/2019	22/12/2019	29/12/2019	05/01/2020
Wind Load Factor required to cause a System Level NRAPM	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
Probability of seeing Wind load factor above	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Wind Load Factor required to cause a Scotland Level NRAPM	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
Probability of seeing Wind load factor above	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%

The forecast is meant as a guide and does not take into account action on pump storage or Interconnectors which will be done as required in control room timescales.
The RAG for the 2-14 National level is based on a surplus higher than 1000MW for green, between 500 and 1000MW for amber and less than 500MW for Red it includes a MW level away from the risk.
The RAG for the 2-14 Scottish level is based on a surplus higher than 400MW for green, between 0 and 400MW for amber and below 0MW for Red it includes a MW level away from the risk.

The weekly 2-52 RAG is the load factor of wind required to cause an NRAPM and then the % probability of getting this load factor. So the percentage can be read as the probability of an NRAPM for each week in with yellow for between 5% and 20% and Red for over 20%.