Date	14/02 AM	14/02 PM	15/02 AM	15/02 PM	16/02 AM	16/02 PM	17/02 AM	17/02 PM	18/02 AM	18/02 PM	19/02 AM	19/02 PM	20/02 AM	20/02 PM	21/02 AM	21/02 PM	22/02 AM	22/02 PM	23/02 AM	23/02 PM	24/02 AM	24/02 PM	25/02 AM	25/02 PM	26/02 AM	26/02 PM	27/02 AM	27/02 PM	28/02 AM	28/02 PM	01/03 AM	01/03 PM
MW away from risk of System Level NRAPM (Forecast Conditions)																														
MW away from risk of Scotland Level NRAPM (Forecast Conditions)																														

Week Number	08W19	09W19	10W19	11W19	12W19	13W19	14W19	15W19	16W19	17W19	18W19	19W19	20W19	21W19	22W19	23W19	24W19	25W19	26W19	27W19	28W19	29W19	30W19	31W19	32W19	33W19	34W19	35W19	36W19	37W19	38W19	39W19	40W19	41W19	42W19	43W19	44W19	45W19	46W19	47W19	48W19	49W19	50W19	51W19	52W19	01W20	02W20	03W20	04W20	05W20	06W20
Date	24/02/2019	03/03/2019	10/03/2019	17/03/2019	24/03/2019	31/03/2019	07/04/2019	14/04/2019	21/04/2019	28/04/2019	05/05/2019	12/05/2019	19/05/2019	26/05/2019	02/06/2019	09/06/2019	16/06/2019	23/06/2019	30/06/2019	07/07/2019	14/07/2019	21/07/2019	28/07/2019	04/08/2019	11/08/2019	18/08/2019	25/08/2019	01/09/2019	08/09/2019	15/09/2019	22/09/2019	29/09/2019	06/10/2019	13/10/2019	20/10/2019	27/10/2019	03/11/2019	10/11/2019	17/11/2019	24/11/2019	01/12/2019	08/12/2019	15/12/2019	22/12/2019	29/12/2019	05/01/2020	12/01/2020	19/01/2020	26/01/2020	02/02/2020	09/02/2020
Wind Load Factor required to cause a System Level NRAPM	1.36	1.08	1.25	1.05	0.97	1.71	1.65	1.93	1.13	0.92	0.81	0.72	0.75	0.92	0.54	0.92	0.77	0.98	0.84	0.91	0.57	0.98	0.65	0.45	0.92	0.61	0.59	0.84	0.47	0.54	0.57	0.84	0.98	0.75	0.61	0.75	0.92	0.98	1.05	0.98	1.05	1.36	1.47	1.61	1.64	1.36	1.64	1.47	1.52	1.58
Probability of seeing Wind load factor above	5%	8%	5%	5%	9%	0%	0%	0%	3%	5%	8%	8%	8%	3%	17%	3%	5%	3%	3%	5%	3%	3%	5%	8%	3%	8%	21%	3%	4%	3%	3%	3%	3%	5%	3%	5%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%
Wind Load Factor required to cause a Scotland Level NRAPM	2.20	1.88	1.97	1.82	2.05	1.93	1.75	1.93	1.58	1.52	1.80	1.82	1.51	1.36	1.35	1.23	1.36	1.23	1.23	1.23	1.26	1.23	1.23	1.23	1.23	1.34	1.34	1.26	1.36	1.26	1.43	1.64	1.49	1.36	1.49	1.43	1.64	1.64	1.58	1.64	1.58	1.49	1.58	1.82	1.72	1.49	1.72	1.61	1.72	1.68
Probability of seeing Wind load factor above	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

The forecast is meant as a guide and does not take into account action on pump storage or Interconnectors which will be done as required in control room timescales.
The RAG for the 7-14 National level is based on a surplus higher than 1700MW for green, between 900 and 1700MW for amber and less than 900MW for Red it includes a MW level away from the risk
The RAG for the 2-14 Scottish level is based on a surplus higher than 400MW for green, between 0 and 400MW for amber and below 0MW for Red it includes a MW level away from the risk.

The weekly 2-52 RAG is the load factor of wind required to cause an NRAPM and then the % probability of getting this load factor. So the percentage can be read as the probability of an NRAPM for each week in with yellow for between 5% and 20% and Red for over 20%.